

# BROWN UNIVERSITY CAMPUS DECARBONIZATION PLAN

Scope 1 Emissions – Phase 1, August 2018

SUNY / PPAA AND NYAPPA SUMMER CONFERENCE  
July 16-18, 2019 Albany, New York

**RAMBOLL**

Bright ideas. Sustainable change.





# AGENDA

01 Brown University Plans and Status

02 Decarbonization Plan Objectives

03 Decarb Project Planning Process

04 Goals and Scoring Matrix

05 Energy Supply Scenarios  
and Modeling Results

06 Implementation Plan and Schedule


01

# BROWN UNIVERSITY PLANS AND STATUS

# CURRENT STATUS

| PHASE 1                                                                                                                                                                                                                                                                                                                   | PHASE 2<br>BY 2022                                                                                                 | PHASE 3<br>BY 2023-2040                                                                 | PHASE 4<br>2030-2040                                        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|-------------------------------------------------------------|
| <p>2008 Pledge – 42% below 2007 Levels by 2020</p> <p>Currently 28% below 2007 levels – <i>established new baseline of 67% below 2007</i></p> <p>100% Renewable Electricity supply with 40 MW Solar PV and 8 MW Wind</p> <p>Thermal Efficiency Project (TEP) – Remove steam from buildings and lower loop temperature</p> | <p>75% Reduction by 2025 and Carbon Neutral by 2040</p> <p>Liquid Biofuel conversion for Central Plant boilers</p> | <p>Building renovations and improvements</p> <p>Enable low temperature heating loop</p> | <p>Identify and implement Carbon Neutral energy sources</p> |

# BROWN'S EMISSIONS TRAJECTORY




2017-2018

28% Below 2007

- Fuel switching
- Energy Conservation Initiatives

# BROWN'S EMISSIONS TRAJECTORY




2017-2018

A New Baseline  
*Remaining Emissions*

- Electricity  
26,500 MT
- Central Heat Plant  
16,500 MT
- Off Loop Buildings  
9,500 MT

# BROWN'S EMISSIONS TRAJECTORY



PHASE 1


2020

67 % Below 2007

50 % Below 2017-18

- Thermal Efficiency Project
- 40MW Solar in RI
- 8 MW Wind in Texas

# BROWN'S EMISSIONS TRAJECTORY




BEYOND 2020

## PHASE 2

- Recycled bio-oil for CHP (2023)
- 75% Below 2017-18



# BROWN'S EMISSIONS TRAJECTORY




BEYOND 2020

## PHASE 3

- Building renovations / loop modifications (2021-2038)
- Lower loop temperature to 185°F

# BROWN'S EMISSIONS TRAJECTORY




BEYOND 2020

## PHASE 4

- 185°F water opens up heating options
- Installation of Heat Pumps (2040)
- A long term, scalable, sustainable solution

# BROWN'S EMISSIONS TRAJECTORY



BEYOND 2020

## PATH TO ZERO

- Emissions from off loop buildings offset after 2040

# OFF LOOP BUILDINGS

Gradually transition 130 buildings off fossil fuels

Maintain campus operations

Incorporate into ongoing building and boiler renewal

Prioritize larger and higher value buildings

Explore connecting additional buildings to the loop

Leverage other renovations



02

# DECARBONIZATION PLAN OBJECTIVES

# DECARBONIZATION RFP SCOPE OF SERVICES

## SCOPE 1 EMISSIONS

- 98 Buildings (4.6M sf) connected to central loop represent 77 %
- Remaining 120 off loop buildings (1.9M sf) represent 23 %
- 3 Large off loop buildings also included


## SCOPE OF SERVICES

|        |                                                   |
|--------|---------------------------------------------------|
| TASK 1 | Work Plan Development - Schedule, approach, goals |
| TASK 2 | Evaluate Existing Conditions                      |
| TASK 3 | Analysis / Modeling / Conceptual Design           |
| TASK 4 | Cost Estimating & Scheduling                      |
| TASK 5 | Phasing Master Plan                               |
| TASK 6 | Final Report and Deliverables                     |


03

# PLANNING PROCESS

# ENERGY MASTERPLANNING PROCESS



# RAMBOLL PLANNING PROCESS



04

# GOALS AND SCORING MATRIX



# GOALS AND SCORING MATRIX

| Weighted Goals and Matrix - Project Evaluation and Scoring |          |                                                        |                                                          |                                                         |                                           |                                     |
|------------------------------------------------------------|----------|--------------------------------------------------------|----------------------------------------------------------|---------------------------------------------------------|-------------------------------------------|-------------------------------------|
| Top Level                                                  |          | 1. Air source heat pumps (ASHP) + peaking boilers (PB) | 2. ASHP + Heat recovery chillers (HRC) + peaking boilers | 3. ASHP + HRC + river water heat pump + peaking boilers | 4. ASHP + HRC + biomass + peaking boilers | 5. ASHP + biomass + peaking boilers |
| Category                                                   | % Weight |                                                        |                                                          |                                                         |                                           |                                     |
| Solution Economics                                         | 30       | 19                                                     | 19                                                       | 17                                                      | 22                                        | 24                                  |
| Solution Risk                                              | 10       | 7                                                      | 7                                                        | 6                                                       | 10                                        | 10                                  |
| Environmental Impact                                       | 40       | 37                                                     | 38                                                       | 34                                                      | 36                                        | 35                                  |
| Social Impact                                              | 10       | 6                                                      | 6                                                        | 6                                                       | 6                                         | 6                                   |
| Economic Development                                       | 3        | 2                                                      | 2                                                        | 2                                                       | 3                                         | 3                                   |
| Reputational Impact                                        | 7        | 7                                                      | 6                                                        | 5                                                       | 6                                         | 7                                   |
|                                                            | 100      | 78                                                     | 78                                                       | 70                                                      | 83                                        | 85                                  |

05

# ENERGY SUPPLY SCENARIOS AND MODELLING RESULTS

# TECHNOLOGIES EVALUATED

|                                                            |                                                                                 |
|------------------------------------------------------------|---------------------------------------------------------------------------------|
| Air source heat pumps                                      |                                                                                 |
| River Water heat pumps                                     |                                                                                 |
| Ground source heat pumps                                   | → <i>Eliminated – no viable aquifer or land for district scale system</i>       |
| Heat recovery chillers including seasonal storage          | → <i>Limited due to chilled water network</i>                                   |
| Solar Thermal including seasonal storage                   | → <i>Eliminated due to space needed and fractional contribution</i>             |
| Biomass (heat only, cogeneration will be described)        |                                                                                 |
| Boilers based on bio-oil, green natural gas or natural gas |                                                                                 |
| Thermal Storage options                                    | → <i>Should be included in each scenario</i>                                    |
| Electric Boilers for Peaking                               | → <i>Eliminated due added 9-12 MW of electrical loading during peak periods</i> |
| Virtual electricity storage                                | → <i>Eliminated due to space needed, high CAPEX, and technology risk</i>        |




# AIR SOURCE HEAT PUMPS

## PROS

- Easy to install and maintain - scalable
- Should fit within existing CEP area

## CONS

- 16,000-30,000 sq ft of space needed (can be split up)
- Noise
- Increased Electrical load 7.5 MW to 22.5 MW peak
- Performance drops off in winter months



| Scenario                           | 20 MW  | 15 MW  | 10 MW |
|------------------------------------|--------|--------|-------|
| Heating demand (MMBtu/hr)          | 68     | 51     | 34    |
| Electricity consumption (MW)       | 6.7    | 5      | 3.3   |
| Space for Air coolers (ft2)        | 15,500 | 11,600 | 7,800 |
| Space for heat pump building (ft2) | 14,000 | 10,500 | 7,000 |


# RIVER WATER HEAT PUMPS

## PROS

- Improved performance over ASHP
- Less noise & space needed (no coolers)
- Scalable

## CONS

- No easy route - “In Street” option in CAPEX
- Below 38° F limits performance and causes Icing – January and February are a concern
- 10% Sea water - corrosive
- Federal 316 a & b permits needed
- (4) State permits needed
- Abandoned Rail Tunnel possibly owned by the State of RI currently




# HEAT RECOVERY CHILLERS

## PROS

- Leverage existing chilled water system
- Upgrade / Replace Existing Chillers
- Flatter performance curve
- Scalable

## CONS

- Existing Chilled Water network limits size and contribution
- Must expand Chilled Water network to increase contribution
- HRC require more maintenance than electric units
- Requires thermal storage



Utilizes waste heat from other process

Couple chilled water system and heating system

- Waste heat from the chiller contributes to heating network
- Cooling effect of heating network helps chilled water system






# BIOMASS CHP / COGEN

## PROS

- Carbon neutral fuel
- Onsite Electric production (offsets heat pumps)
- Most cost effective solution
- Electrical distribution system upgrades not required

## CONS

- Space requirements and retrofit of existing CEP or new build on new land
- Noise / Dust / Truck traffic (15-20 trucks per day)
- Combustion process and by products
  - Ash
  - Some carbon emissions plus NOx



# BIOFUEL (LIQUID) CONVERSION OF CEP BOILERS

## PROS

- Timeframe – can be done now and within 2 years
- Carbon neutral depending on source
- Extends time period to evaluate other technologies
- Conversion is not complex

## CONS

- Added cost of boiler burner and forwarding system conversion
- Wholesale change for all 3 boilers (redundancy)
- Added truck traffic during peak heating season



Convert existing boilers to burn liquid biofuel

Several biofuels are available in NE

- Post consumer options available



LARGEST CHALLENGE  
OR IMPACT

# HYDRAULIC MODEL – HEATING NETWORK EVALUATION

Network Parameters (current  $\Delta 20^\circ \text{ F}$  from ecosystems TEP Model):

Model Result, Central Heat Plant:

- Flow: ~ 5460 gpm
- Power, Thermal: ~ 110,430 MBH
- Pressure, Supply: ~ 270 psi(g)
- Pressure, Return: ~ 14.5 psi(g)
- Temperature, Supply: ~ 185 °F
- Temperature, Return: ~ 144 °F

Distribution Network:

- Maximum pressure: ~ 270 psi(g)
- Minimum pressure: ~ 15 psi(g)
- Minimum  $\Delta P$ : ~ 14.5 psi (Graduate Center E)

- High Flows and supply pressure above 300 psig (equipment limits)
- Pressure gradients in system exceed safety limits due to increased flows

## OPTIONS

Increase pipe sizes


OR

Increase Delta T in buildings



# HYDRAULIC MODEL – HEATING NETWORK EVALUATION

## WITH LESS THAN 40°F $\Delta T$




Invest \$80-100M in Piping Network Upgrades

Less than less than 40 ° F  $\Delta T$  - poor performing buildings

Increased pumping and electrical costs

## WITH MORE THAN 40°F $\Delta T$



Invest \$60-80M in Buildings Upgrades

More Efficient Buildings and Optimized Network

Lower CAPEX and OPEX

Buildings may already be slated for upgrades



# HYDRAULIC MODEL – HEATING NETWORK EVALUATION

## Increased Building Delta T to 40° F

### Model Result, Central Heat Plant:

- Flow: ~ 3836 gpm
- Power, Thermal: ~ 110,370 MBH
- Pressure, Supply: ~ 110 psi(g)
- Pressure, Return: ~ 14.5 psi(g)
- Temperature, Supply: ~ 185 °F
- Temperature, Return: ~ 127 °F

### Distribution Network:

- Maximum pressure: ~ 110 psi(g)
- Minimum pressure: ~ 15 psi(g)
- Minimum ΔP: ~ 14.5 psi (Graduate Center E)

## Buildings with Delta T less than 40 ° F

- Heat exchangers and HVAC
- 54 New Buildings in total
- Included in CAPEX

| FAMIS  | Building name                  | Likely MTHW return temp | Resulting DT | BAS Notes related to likely MTHW return temp. Notes are on building that host the hub hardware                                                                                                                                                                                                                                                                                                                                      |
|--------|--------------------------------|-------------------------|--------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 100144 | ANGELL ST 164                  | 165.00                  | 15.00        | Building is under construction. During initial review Brown had requested the EstmmBTU for 164Angell be increased from 3218 to 2963. Please adjust along with Es. MBH                                                                                                                                                                                                                                                               |
| 100230 | ANNMARY BROWN MEMORIAL LIBRARY | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 100258 | ARCHIBALD-BRONSON: KEENEY QUAD | 160.00                  | 20.00        | Again hard to get a read on return temps in BAS - only about a 12 degree drop. If it achieves 180 we may only see 168 coming back. TEP revising for 200F supply from Wayland, supply space heating, then cascade through makeup air. Hard to gauge future temps. May be supply of 200 and return of ~160                                                                                                                            |
| 100278 | ARNOLD LAB                     | 145.00                  | 35.00        | Andover                                                                                                                                                                                                                                                                                                                                                                                                                             |
| 100077 | BARUS & HOLLEY                 | 150.00                  | 30.00        | Barus & Holley. MTHWR-T use 150F. HAZO has reset of 130-160. During cold weather in January the HWR-T was 140-145 so we can use 145 for that. It appears there may be some radiation return in January of about 150F (dual temp stuff). May want to use 150 for the building unless I can parse that apart.                                                                                                                         |
| 100143 | BLISTEIN HOUSE                 | 145.00                  | 35.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 100174 | BUXTON HOUSE: WRISTON QUAD     | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 100163 | CHAPIN HOUSE: WRISTON QUAD     | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 100164 | DIMAN HOUSE: WRISTON QUAD      | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 100331 | ENGINEERING RESEARCH CENTER    | 160.00                  | 20.00        | Engineering Research Center: MTHWR-T of 160. Running on the boilers. Last January return temps in the mid 160s with supply setpoint at 180. Reset is supposed to be 120-180. However, even at 180 still seeing return at 165. Troubling. Not much for mechanical drawings to know what the coils are rated for. Had to look in progress prints. AHU coils are rated for entering water of 180 and leaving of 160. I think it's 160. |

# UPGRADES TO BUILDINGS – 2 GROUPS

## 8 BUILDINGS ON STEAM POST TEP

| Buildings not designed for MTHW at or below 180 °F |
|----------------------------------------------------|
| Alumnae Hall                                       |
| Andrews House                                      |
| Caswell Hall                                       |
| Gardner House                                      |
| Hegeman Hall                                       |
| John Hay Library                                   |
| Maxcy Hall                                         |
| Sharpe Refectory                                   |

## 54 BUILDINGS INCREASE $\Delta T$

| FAMS   | Building name                  | Likely MTHW return temp | Resulting DT | BAS Notes related to likely MTHW return temp. Notes are on building that has the Hub hardware                                                                                                                                                                                                                                                                                                                                  |
|--------|--------------------------------|-------------------------|--------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 300544 | ANGELL ST 164                  | 165.00                  | 15.00        | Building is under construction. During initial review Brown had requested the ExtremBTO for 164Angell be increased from 3238 to 2963. Please adjust along with Es. MBH                                                                                                                                                                                                                                                         |
| 300230 | ANNMAY BROWN MEMORIAL LIBRARY  | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
|        | ARCHIBALD-BRONSON; KEENEY QUAD | 160.00                  | 20.00        | Again hard to get a read on return temps. BAS - only about a 12 degree drop. If it achieves 180 we may only see 165 coming back. TEP revising for 2005 supply from Wayland, supply space heating, then cascade through makeup air. Hard to gauge future temps. May be supply of 200 and return of ~160                                                                                                                         |
|        | OLD LAB                        | 145.00                  | 35.00        | Andover has reset of 130-160. During cold weather in January the HWB-T was 140-145 so we can use 145 for that. It appears there may be some radiation return in January of about 150F (dual temp stuff). May want to use 150 for the building unless I can parse that apart.                                                                                                                                                   |
| 300077 | BARUS & HOLLEY                 | 150.00                  | 30.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 300543 | BLUSTEIN HOUSE                 | 145.00                  | 35.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 300574 | BUXTON HOUSE; WRISTON QUAD     | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 300563 | CHAPIN HOUSE; WRISTON QUAD     | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 300564 | DEMAN HOUSE; WRISTON QUAD      | 160.00                  | 20.00        |                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 300331 | ENGINEERING RESEARCH CENTER    | 160.00                  | 20.00        | Engineering Research Center: MTHWB T of 160. Running on the boilers. Last January return temps in the mid 160s with supply setpoint at 180. Reset is supposed to be 120-180. However, even at 180 still seeing return at 165. Troubling. Not much for mechanical drawings to know what the coils are rated for. Had to look in progress prints. AHU coils are rated for entering water of 180 and leaving of 160. I think it's |

4 Buildings Overlap

Good information on existing conditions

|    |                                                                              |     |              |
|----|------------------------------------------------------------------------------|-----|--------------|
| B- | Building works (independent of scenario / production technology)             |     | \$38.402.220 |
| B1 | Hub ETS modifications                                                        | 24% | \$2.932.371  |
| B6 | Replacement of shell-and-tube heat exchangers in SMTHW buildings on the Loop | 24% | \$1.083.099  |
| B2 | Production of DHW with MTHW from the Loop                                    | 30% | \$546.021    |
| B3 | Conversion of LPS heated buildings to MTHW                                   | 30% | \$18.705.310 |
| B4 | Increase temp. diff in selected buildings                                    | 30% | \$15.135.419 |
| B5 | Installation of heat pumps in off-loop buildings                             |     | \$0          |

# COMPARING RESULTS



# EMISSIONS COMPARISON – TONS PER YEAR

## CARBON NEUTRAL ELECTRIC PPA

| Technology     | Scenario 1 | Scenario 2 | Scenario 3 | Scenario 4 | Scenario 5   | Scenario 6   |
|----------------|------------|------------|------------|------------|--------------|--------------|
| ASHP (MMBtu/h) | 0          | 0          | 0          | 0          | 0            | 0            |
| HRC (assumed)  | 0          | 0          | 0          | 0          | 0            | 0            |
| RWHP           | 0          | 0          | 0          | 0          | 0            | 0            |
| Biomass        | 0          | 0          | 0          | 644        | 1.184        | 1.546        |
| Peaking        | <u>146</u> | <u>122</u> | <u>141</u> | <u>111</u> | <u>96</u>    | <u>74</u>    |
| <b>TOTAL</b>   | <b>146</b> | <b>122</b> | <b>141</b> | <b>755</b> | <b>1.281</b> | <b>1.620</b> |

## CARBON OF CURRENT ISO NE GRID

| Technology    | Scenario 1  | Scenario 2  | Scenario 3  | Scenario 4  | Scenario 5  | Scenario 6  |
|---------------|-------------|-------------|-------------|-------------|-------------|-------------|
| ASHP          | 6.680       | 5.505       | 4.594       | 4.119       | 2.301       | 703         |
| HRC (assumed) | 0           | 368         | 0           | 0           | 0           | 0           |
| RWHP          | 0           | 0           | 1.820       | 0           | 0           | 0           |
| Biomass       | 0           | 0           | 0           | 644         | 1.184       | 1.546       |
| Peaking       | <u>146</u>  | <u>122</u>  | <u>141</u>  | <u>111</u>  | <u>96</u>   | <u>74</u>   |
| <b>TOTAL</b>  | <b>6826</b> | <b>5994</b> | <b>6554</b> | <b>4875</b> | <b>3581</b> | <b>2323</b> |



# ANNUAL OPEX

ANNUAL FUEL COSTS (\$) Can be reduced with Net Metering or new PPA

| Technology     | Scenario 1 | Scenario 2 | Scenario 3 | Scenario 4 | Scenario 5   | Scenario 6   |
|----------------|------------|------------|------------|------------|--------------|--------------|
| ASHP (MMBtu/h) | 0          | 0          | 0          | 0          | 0            | 0            |
| HRC (assumed)  | 0          | 0          | 0          | 0          | 0            | 0            |
| RWHP           | 0          | 0          | 0          | 0          | 0            | 0            |
| Biomass        | 0          | 0          | 0          | 644        | 1.184        | 1.546        |
| Peaking        | <u>146</u> | <u>122</u> | <u>141</u> | <u>111</u> | <u>96</u>    | <u>74</u>    |
| <b>TOTAL</b>   | <b>146</b> | <b>122</b> | <b>141</b> | <b>755</b> | <b>1.281</b> | <b>1.620</b> |

VARIABLE OPEX (\$)

| Technology    | Scenario 1  | Scenario 2  | Scenario 3  | Scenario 4  | Scenario 5  | Scenario 6  |
|---------------|-------------|-------------|-------------|-------------|-------------|-------------|
| ASHP          | 6.680       | 5.505       | 4.594       | 4.119       | 2.301       | 703         |
| HRC (assumed) | 0           | 368         | 0           | 0           | 0           | 0           |
| RWHP          | 0           | 0           | 1.820       | 0           | 0           | 0           |
| Biomass       | 0           | 0           | 0           | 644         | 1.184       | 1.546       |
| Peaking       | <u>146</u>  | <u>122</u>  | <u>141</u>  | <u>111</u>  | <u>96</u>   | <u>74</u>   |
| <b>TOTAL</b>  | <b>6826</b> | <b>5994</b> | <b>6554</b> | <b>4875</b> | <b>3581</b> | <b>2323</b> |

# ELECTRICAL LOAD INCREASE

| Maximum electric capacity in the scenarios, in MW |      |     |      |      |               |                |                     |                      |
|---------------------------------------------------|------|-----|------|------|---------------|----------------|---------------------|----------------------|
| Electric capacities                               | ASHP | HRC | RWHP | BIOM | Peaking (oil) | Peaking (elec) | Backup boiler (oil) | Backup Boiler (Elec) |
| Scenario 1                                        | 7.5  | 0.0 | 0.0  | 0.0  | 0.0           | 15.0           | 0.0                 | 30.0                 |
| Scenario 2                                        | 7.5  | 0.0 | 0.0  | 0.0  | 0.0           | 15.0           | 0.0                 | 30.0                 |
| Scenario 3                                        | 5.0  | 0.0 | 2.3  | 0.0  | 0.0           | 15.0           | 0.0                 | 30.0                 |
| Scenario 4                                        | 5.0  | 0.0 | 0.0  | 0.0  | 0.0           | 15.0           | 0.0                 | 30.0                 |
| Scenario 5                                        | 2.5  | 0.0 | 0.0  | 0.0  | 0.0           | 15.0           | 0.0                 | 30.0                 |


- Over and above current consumption
- Air Source Heat Pumps with Biofuel backup – 7.5 MW Peak
- Air Source Heat Pumps / Biofuel Backup / RWHP – 9.8 MW Peak
- Scenario 6 82% Biomass – less than 2.5 MW
- Electric Boilers for peaking and backup adds 15 MW
- Initial evaluation – new feeder from National Grid required for 7.5 – 10 MW

06


# IMPLEMENTATION PLAN

# POSSIBLE PHASING & SEQUENCING

- Leverage existing systems
- Reduce cost & carbon while minimizing investment
- Reduce Risk
  - Mitigate technology concerns
  - Test and trial technologies
- Phased in over time



# IMPLEMENTATION & PHASING PLAN



# THANK YOU

DAVE LARSON

Energy Project Manager, Office of Sustainability  
arthur\_larson@brown.edu

DANIEL KELLEY

General Manager - Energy Systems N. America  
dkelley@ramboll.com

# LEARNING OBJECTIVE QUESTIONS



## QUESTION 1

Identity the types of projects that Brown University has included in their plan to reduce energy and carbon emissions.



# LEARNING OBJECTIVE QUESTIONS



## ANSWER

- Thermal efficiency project
- Off-site solar and wind purchase agreements
- Recycled bio-oil for CHP
- Building renovations
- Loop modifications
- Lower temperature loop
- Heat pumps
- Thermal storage

# LEARNING OBJECTIVE QUESTIONS



## QUESTION 1

What benefits can be realized from utilizing energy scenario planning modeling software?

## LEARNING OBJECTIVE QUESTIONS



### ANSWER

The modeling software can help assess various carbon reduction scenarios based on technology, life cycle cost, carbon reduction, and interactive impacts.

## LEARNING OBJECTIVE QUESTIONS



### QUESTION 3

Identify pros and cons of using air source heat pumps.

# LEARNING OBJECTIVE QUESTIONS



## ANSWER

### PROS

- Easy to install and maintain
  - scalable
- Should fit within existing CEP area

### CONS

- 16,000-30,000 sq ft of space needed (can be split up)
- Noise
- Increased Electrical load 7.5 MW to 22.5 MW peak (Scope 2 emissions increase as a result)
- Performance drops off in winter months